

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

SOLATUBE International, Inc.
2210 Oak Ridge Way
Vista, CA 92081

Attn: Dan State
(760) 597-4400

RESEARCH REPORT: RR 25251
(CSI #08620)

BASED UPON ICC-ES VALUATION
REPORT No. ESR-2253

REEVALUATION DUE DATE:
April 1, 2010
Code: 2008 LABC
Issued: April 1, 2008

GENERAL APPROVAL – Reevaluation / Clerical Modification - Technical
Modification - Solatube Tubular Daylight Device (TDD) Skylights.

DETAILS

The above products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. ESR- 2253, dated July 1, 2008, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made a part of this general approval.

The parts of Report No. ESR-2253 marked by the asterisks are modified by the Los Angeles Building Department from this approval.

The approval is subject to the following conditions:

1. Installation must comply with this report, the manufacturer's published installation instructions and 2008 Los Angeles Building Code Sections 2405, 2606, and 2610.
2. The maximum positive and negative allowable loads are as described in Section 4.3 of ESR-2253.
3. Solatube Tubular Daylight Device (TDD) Skylights are produced in Vista, California, under a quality control program with inspections by Underwriters Laboratories Inc. (AA-669).

RR 25251
Page 1 of 2

SOLATUBE International, Inc
RE: SOLATUBE Tubular Skylights

4. Where a Class A, B, or C roof covering is required, skylight dome edges for the 10- and 14-inch-diameter skylights must be protected with the application of galvanized or aluminized steel dome-edge protective rings, as shown in Figure 1 of Evaluation Report No. ESR-2253. Dome-edge protective rings are not required for the 21-inch-diameter skylights with 8- or 11-inch high flashing, or any model with curb-mount flashing on curbs a minimum of 8 inches high.

DISCUSSION

The technical modification is to change the reference ICC-ES report No. from ESR-1334 to ESR- 2253 and update it to be in compliance with 2008 Los Angeles Building Code.

The Clerical Modification is to change the contact person and the telephone number.

This approval is based on test base on AC-16, dated February, 2008.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

YEUAN CHOU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone (213) 202-9812
Fax (213) 202-9942

RB:elcm
RR25251 /MSW
R04/01/08
2B1/2405/2606/2610

Attachments: Details and Specifications (5 Pages)

RR 25251
Page 2 of 2